





CERTIFICATE

No. Z1A 057396 0939 Rev. 01

Holder of Certificate: XP Power LLC.

340 Commerce, Suite 100 Irvine CA 92602

USA

Certification Mark:





Product: Switch mode power supplies

Tested according to: EN 62368-1:2014/A11:2017 AfPS GS 2019:01 PAK

With this certificate, in its capacity as a notified GS body, TÜV SÜD Product Service GmbH issues the GS Mark to the named certificate holder for the declared product with the named model designation in accordance with section 20 ProdSG (German Product Safety Act). The product meets the safety and health requirements of section 20 (3) ProdSG. The manufacturer is reminded of their obligations in accordance with section 24 ProdSG. The certification marks shown above can be affixed on the product. It is not permitted to alter the certification marks in any way. In addition, the certificate holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 7191320618/02-TR

Valid until: 2026-01-07

Date, 2024-07-08

(Kim Hock Teo)



CERTIFICATE

No. Z1A 057396 0939 Rev. 01

Model(s): ALM200PSXXC2-ZZ

where XX can be 12, 15, 19, 24, 48 designating output voltage
where -ZZ can be blank or -A,-8,-8A designating AC inlet
Models may have additional identifier designating casing colour

or for marketing purpose only.

Brand Name: XP

Parameters:

Rated Input: 100-240 Vac, 2.4A, 50/60 Hz, Class II

Degree of Protection (IP): 32

Operating environment maximum temperature specified by the manufacturer is +40°C for full

load condition and +60°C for load condition derating to 70W.

Rated output

ALM200PS12C2-ZZ: 12 Vdc, 16.7 A ALM200PS15C2-ZZ: 15 Vdc, 13.4 A ALM200PS19C2-ZZ: 19 Vdc, 10.6 A ALM200PS24C2-ZZ: 24 Vdc, 8.4 A ALM200PS48C2-ZZ: 48 Vdc, 4.2 A